


$$H_{2000daNm} = 1,6m; c_{2000daNm} = 1,0m$$

$$H_{4000daNm} = 1,9m; c_{4000daNm} = 1,2m$$

L (m)	8,0	8,5	9,0	9,5	10,0	10,5	11,0	11,5	12,0
a (m)	1,9	2,0	2,1	2,2	2,3	2,4	2,5	2,6	2,7
b (m)	2,9	3,0	3,1	3,2	3,3	3,4	3,5	3,6	3,7
$Q_{IZKOP} (m^3)$ za 2000daNm	6,2	6,4	6,6	6,7	6,9	7,0	7,2	7,4	7,5
$Q_{IZKOP} (m^3)$ za 4000daNm	8,9	9,1	9,4	9,6	9,8	10,0	10,3	10,5	10,7

Sprememba		Opis spremembe		Datum:		Podpis:	
 <b>Elektro Celje, d.d.</b> Vrunčeva 2a, 3000 Celje				Objekt/lokacija:			
Investitor: ELEKTRO CELJE, d.d. Vrunčeva 2a 3000 Celje				Vsebina/naslov risbe:  <b>Temeljenje lesenih A-drogov v betonskih kleščah</b>			
Odg. projektant:		Ime in priimek:		Id. št.:		Podpis:	
Izdelal:							
Kontroliral:							
<input type="checkbox"/> <input checked="" type="checkbox"/>		Merilo:		Datum:		Vrsta projekta:	
						Risba št.:	
						St./od st. <b>1/1</b>	