


ŠTEVILO CEVI	H (m)	H ₁ (m)	H ₂ (m)	Q _{IZKOP} (m ³ /m)	Q _{BETON(PESEK)} (m ³ /m)
2	0,80	1,025	0,70	0,46	0,11
	1,00	1,225	0,90	0,55	
	1,20	1,425	1,10	0,64	
3	0,80	1,025	0,70	0,62	0,14
	1,00	1,225	0,90	0,74	
	1,20	1,425	1,10	0,86	
4	0,80	1,19	0,70	0,54	0,15
	1,00	1,39	0,90	0,63	
	1,20	1,59	1,10	0,72	
6	0,80	1,19	0,70	0,71	0,20
	1,00	1,39	0,90	0,83	
	1,20	1,59	1,10	0,96	

Sprememba		Opis spremembe		Datum:		Podpis:	
 Elektro Celje, d.d. Vrunčeva 2a, 3000 Celje				Objekt/lokacija:			
Investitor: ELEKTRO CELJE, d.d. Vrunčeva 2a 3000 Celje				Vsebina/naslov risbe: Prerez kableske kanalizacije Ø 125 mm			
Odg. projektant:		Ime in priimek:		Id. št.:		Podpis:	
Izdal:						Vrsta načrta:	
Kontroliral:						Vrsta projekta:	
<input type="checkbox"/> ⊕		Merilo:		Datum:		Risba št.:	
						St./od st. 1/1	